

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-0026:249 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Simplex Time Recorder, 100 Simplex Drive, Westminter, MA 01441
Contact: Paul D. Mattern (978) 731-8542

DESIGN: Models 4903-9252, -9253, -9254, -9255, -9256, -9257, and -9258 horn/strobes. Units are switch-selectable as free running or synchronized. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 24 VDC
Candela: -9252, -9255, -9257: 15cd
-9253: 30cd
-9254, -9256, -9258: 110cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as electronic horn/strobes for use with separately listed electrically compatible fire alarm control units. For indoor use only.

This unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996.

01-17-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager